



Georgetown Township Fire Department

Date: March 5, 2007
To: Supervisor Holland
Subject: Monthly Fire Runs

The Georgetown Township Fire Department responded to a total of 34 runs for the month of February 2007, with an average response time of 5.07.

Dan Hamming
Georgetown Township Fire Chief

Georgetown Fire Dept

Incident List by Alarm Date/Time

Alarm Date Between {02/01/2007} And {02/28/2007}

Incident-Exp#	Alm Date	Alm Time	Location	Incident Type
07-0000038-000	02/01/2007	22:13:00	7741 Coconut DR	600 Good intent call, Other
07-0000039-000	02/02/2007	17:35:00	4053 New Holland ST	352 Extrication of victim(s)
07-0000040-000	02/03/2007	06:27:00	7025 Kenowa AVE	321 EMS call, excluding vehicle
07-0000041-000	02/03/2007	12:24:00	Brairwood AVE & Bauer RD	138 Off-road vehicle or heavy
07-0000045-000	02/05/2007	01:03:00	Port Sheldon ST & Center	162 Outside equipment fire
07-0000042-000	02/05/2007	05:12:00	44th ST & 8th AVE	744 Detector activation, no fire
07-0000043-000	02/05/2007	08:11:00	7459 Boulder Bluff DR	311 Medical assist, assist EMS
07-0000046-000	02/05/2007	10:12:00	7380 12th AVE	321 EMS call, excluding vehicle
07-0000044-000	02/05/2007	12:02:00	Baldwin ST & Coconut DR	444 Power line down
07-0000047-000	02/06/2007	20:54:00	2140 Bauer RD	331 Lock-in (if lock out , use
07-0000048-000	02/08/2007	16:07:00	725 Baldwin ST	611 Dispatched & cancelled en
07-0000058-000	02/09/2007	08:20:00	725 Baldwin ST	311 Medical assist, assist EMS
07-0000050-000	02/09/2007	18:13:00	7626 Lamplight DR	746 Carbon monoxide detector
07-0000049-000	02/09/2007	23:29:00	6497 Lily ST	424 Carbon monoxide incident
07-0000051-000	02/10/2007	04:58:00	1377 Bent Tree DR	321 EMS call, excluding vehicle
07-0000053-000	02/11/2007	23:57:00	725 Baldwin ST	321 EMS call, excluding vehicle
07-0000052-000	02/12/2007	11:55:00	7996 Green Meadow CT	424 Carbon monoxide incident
07-0000054-000	02/12/2007	12:36:00	2110 Pinewood ST	443 Breakdown of light ballast
07-0000057-000	02/13/2007	09:34:00	1814 Baldwin ST	815 Severe weather or natural
07-0000056-000	02/13/2007	11:21:00	7394 12th AVE	321 EMS call, excluding vehicle
07-0000059-000	02/13/2007	19:03:00	1515 Baldwin ST	571 Cover assignment, standby,
07-0000055-000	02/13/2007	22:27:00	8627 Cedar Lake DR	424 Carbon monoxide incident
07-0000060-000	02/14/2007	16:00:00	625 Summerset DR	311 Medical assist, assist EMS
07-0000061-000	02/14/2007	20:00:00	2140 Bauer RD	522 Water or steam leak
07-0000062-000	02/16/2007	18:04:00	Cottonwood DR & Honeybrook	411 Gasoline or other flammable
07-0000063-000	02/19/2007	11:22:00	6946 Maier AVE	321 EMS call, excluding vehicle
07-0000065-000	02/21/2007	12:37:00	598 Baldwin ST	745 Alarm system activation, no
07-0000064-000	02/21/2007	15:09:00	957 Parsons ST	321 EMS call, excluding vehicle
07-0000068-000	02/25/2007	20:34:00	2169 Pine Ridge DR	111 Building fire
07-0000067-000	02/26/2007	01:32:00	3558 Nobb Hill DR	321 EMS call, excluding vehicle
07-0000066-000	02/26/2007	01:37:00	' Riverbend DR	321 EMS call, excluding vehicle
07-0000069-000	02/27/2007	12:38:00	2221 Tyler ST	424 Carbon monoxide incident
07-0000070-000	02/27/2007	15:32:00	4482 Port Sheldon ST	700 False alarm or false call,
07-0000071-000	02/27/2007	21:06:00	2766 Baldwin ST	412 Gas leak (natural gas or

Total Incident Count 34

Georgetown Fire Department

Maintenance Report

February 2007

Calls

EMS: 4
Alarms: 1
CO:
Spills: 1
Others: 3

Parks and Cemetery

(3hrs) 2-26-07 Rod, Plowing lift stations

Miscellaneous

Plow stations
4 fire prevention tours at station 3
Repair 831 portable generator
Drain gas and refuel Emergency Services Generators
Refuel Emergency Services Gas cans
Rebuild Emergency Service generator at station 1
Pin door locks at all 3 stations
Work on Key fobs and security reports
Mount new SCBA bracket on 825 front LT seat
Refuel all gas cans with Premium gas for small engines at the stations
SCBA maintenance for station 3, cleaning masks and checking SCBA packs
Remount radio in the electrical room at station 1
Remount repaired radio in 823
Get rid of debris in front storage room at station 1
Car Seat event at station 2
Repair portable Generator at station 3
Repair spare Extraction power unit at station 1
Replace bad sensor eye in hand dry in ladies bathroom station 3
Work on front door at station 2
Empty cigarette containers at all stations.
Repair Air eject broke on 824
Repair to Generator on engine 824
Repair leaky pipe in Compressor Room at station 1.
Work on Security reports
Helped water sewer with manhole repair
Helped block traffic for Harold's water project
Repair K-12 saw station 2

Georgetown Township Fire Department Fire Inspector Activity Report

February 2007

Calls

FIRE:	01
ALARM:	03
MEDICAL:	06
PI:	
PI PIN-IN:	
CO:	02
U-BURN:	
SPILL:	
OTHER:	03
TOTAL:	15

Inspections

MAINTENANCE:	
FOLLOW UP:	05
COMMERCIAL WITH PCI:	04
ZONING COMPLIANCE:	01
TOTAL:	10

Education

- Attended the 9th Annual Michigan Fire Inspectors Society Winter Educational Seminar. This was held at the MSU Kellogg Conference Center in East Lansing.

Fire Investigation and Follow Up

- Stopped by the HomeFront Church, 6268 – 8th Ave, to talk to the staff about the fire alarm we had at their facility. Advised them that their duct detectors needed to be cleaned a minimum of once a year to eliminate false alarms like the one we had the morning of February 5.
- Investigated the fire we had at the construction site at 2187 Port Sheldon. This fire involved a commercial heating blanket that the masons used to keep the sand from freezing. I talked to the owner of the business and he told me that these blankets do wear out after numerous folding which breaks the little wires inside. He told me that this is the first time he has had one catch fire. Usually they just short out and trip the breaker on the circuit they're plugged into. He told me they'll be throwing the blanket away and purchasing a new one. The damage was confined to the blanket.
- Thursday the 15th: Met with cause and origin investigators at the scene of the house fire at 1958 New Castle. Those in attendance for the home owners insurance company were Jim Curran, fire investigator from Ken Shelley Associates and N. Jay Herrick, Jr., P.E., electrical engineer from Fire & Failure Forensics, LLC. The investigator representing the Brother Company, manufacturers of the computer printer, was Ryan M. Cox from Kodiak Enterprises, Inc.
- Tuesday the 27th: Chief Hamming, Fire Fighter Ryan Cooke and I met with the fire investigators at Boyne Machine Company, 2169 Pine Ridge Drive. Ottawa County Sheriffs Department, Michigan State Police and Citizens Insurance Company will do this fire investigation. Ottawa County will take the lead in this investigation. Georgetown Fire will assist these investigators with equipment, etc.

Other

- Learning Ship Christian preschool came to station 3 for a tour.
- Attended the monthly staff meeting with Chief Hamming and F.F. Matt DeWitt.
- Followed up on complaints we received about neighbors covering up their fire hydrant with snow after they had just shoveled it out.
- Had a meeting with Chuck Dyk at PCI in reference to the fire alarm test at Chapel Pointe Church.
- Worked on our new standard operating procedure on "Harassment In The Workplace".
- Worked on updating the emergency contact list for local businesses.
- Had Squad 871 serviced.

- Met FedEx at Station 1 to take delivery of the new breathing air compressor. Also met with Roger Engvall from Air-Source-One and the crew who would be installing this air compressor in the station.
- Reviewed the new GEO files that we received from Central Dispatch. Made additions and deletions and brought it to Chief Hamming for him to review them. After Chief Hamming made the final additions and deletions I faxed them back to Central Dispatch so they could update their files.
- Assisted Kim Mulder, Administrator for the Cottonwood Christian Learning Center, with the new fire safety regulations for daycare facilities that the state is imposing upon them.
- Met with Chief Hamming, Deputy Chief Poolman and Captain McIntyre to critique the Maier Street call.
- Met with Chuck Dyk and Loren Serne, from PCI, to review the code sections, in the Michigan Building Code and the International Fire Code, that requires a monitored fire alarm system and then installed per NFPA 72, National Fire Alarm Code. We also went over the code requirements for manual fire alarm boxes in a building that is equipped throughout with an automatic sprinkler system.
- Put together a Business Emergency Contact book Chief Hamming.
- Construction plan review: Jenison Bible Church, 6360 – 14th Ave. After reviewing these plans I met with the general contractor, Mr. Mark Leathhead, owner of Bauer Construction Co. We went over the changes and additions the fire department would be requiring and discussed other changes that they had made after the prints were sent out.
- Met with Harold Zwyghuizen, custodian at Fellowship Reformed Church, to see what the churches plans were for the anticipated crowd for the Blackwood Brothers Concert. I checked all exit doors on the exterior of the building to make sure they were operational and free from snow buildup. I again told Harold that there were to be no chairs in the aisle ways or in the foyer area. He assured me that that would not happen and he would tell the concert committee that I had stopped by.
- Fire Fighter Matt DeWitt and I setup Truck 841 to try and duplicate the stabilizer light problem that we had the night before. We could not duplicate the problem.
- Had a meeting at Station 1 with Chief Hamming, Captain McIntyre and Fire Fighter Josh Butler.

Georgetown Township Fire Department

Fire Prevention Bureau

Monthly Activity Report

February 2007

There were no scheduled or impromptu public relations events during this month.

How Alarms Were Answered - February 2007

