



GEORGETOWN TOWNSHIP FIRE DEPARTMENT

Project Name: Lowing Woods

Submitter: Nevada Creek Development Company

Architect/Designer: Richard A. Pulaski

Project # 25201449

Review Date: 11/4/2025

Reviewer: Craig Scholma, Fire Inspector

After reviewing the distances around the buildings and considering the access difficulties the fence creates, the Georgetown Township Fire Department will require buildings B7-B12 and B21 – B26 to be sprinkled. This requirement is consistent with the 2015 International Fire Code (IFC). The provided prints show the distance in excess of the allowed 150ft. Exemption to this requirement allows distance greater than 150ft where an approved automatic sprinkler system is installed.

Craig Scholma

Fire Inspector

Georgetown Township



Phone

616-226-6015



Email

cscholma@georgetown-mi.gov



Address

1415 14th Avenue Jenison, MI 49428